



VILLAGE OF HILLSIDE

PUBLIC WORKS & BUILDING SERVICES

DIRECTOR
Joseph L. Pisano

ASSISTANT DIRECTOR
Paul J. Smith

FOREMAN
Andre Kwiatek, Water, Sewer & Streets

FOREMAN
Dale Voelker, Maintenance

4151 MAY STREET
HILLSIDE, ILLINOIS 60162
708/547-5540
FAX: 708/547-2582
www.hillside-il.org

BUILDING INSPECTOR
Arthur W. Rubel

PLUMBING INSPECTOR
Jack Caruso

ELECTRICAL INSPECTOR
Willie Carter

CODE ENFORCEMENT OFFICER
Leonard P. Belmonte

VILLAGE OF HILLSIDE CONSTRUCTION CODE WATER TAP SPECIFICATIONS 2006

1. A FULL FACE, STAINLESS STEEL TAPPING SADDLE MUST BE USED TO CONNECT TO THE EXISTING WATER MAIN. DIRECT TAPS ARE NOT ALLOWED.
2. A MUELLER FLARE TYPE CORPORATION STOP IS TO BE INSTALLED ON THE TAPPING SADDLE.
3. 1"-2" TYPE "K" COPPER TUBING IS TO BE INSTALLED AS THE NEW WATER SERVICE LINE
4. A 1"-2" MUELLER 300 BALL CURB VALVE COMPRESSION OR FLARE TYPE ROUNDWAY/CURB STOP IS TO BE INSTALLED AT A LOCATION TWO TO FOUR FEET (2'-4') AWAY FROM THE BACK OF CURB AND IS TO BE LOCATED IN THE VILLAGE PARKWAY.
5. THE ROUNDWAY/CURB STOP IS TO BE HOUSED IN A 2 ½" DIAMETER TYLER 95E ADJUSTABLE SADDLE TYPE SERVICE BOX AND MUST BE LOCATED IN THE VILLAGE PARKWAY.
6. THE SERVICE LINE MUST BE INSTALLED UNDERGROUND IN THE BASEMENT AREA. SERVICE LINES UNDER THE CRAWL SPACE WILL NOT BE ALLOWED TO BE EXPOSED.
7. A PLUMBING SPREAD MUST BE SUPPLIED WITHIN A HEATED ARE TO ALLOW THE PROPER INSTALLATION OF THE SPECIFIED WATER METER.
8. GATE OR BALL TYPE SHUT-OFF VALVES SHALL BE INSTALLED ON EACH SIDE OF THE WATER METER.
9. THE WATER METER AND SHUT-OFF VALVES SHALL BE LOCATED IN AN ACCESSIBLE AREA FOR FUTURE MAINTENANCE.
10. ALL TAPS, CONNECTIONS, AND LOCATIONS MUST BE INSPECTED BY THE HILLSIDE PUBLIC WORKS DEPARTMENT PRIOR TO BACKFILLING.
11. THE WATER SERVICE LINE SHALL BE INSTALLED AT LEAST 18" ABOVE OR 10' LATERALLY FROM THE SANITARY SEWER LINE.
12. ALL WATER SERVICE LINES MUST BE INSTALLED AT LOCATIONS WELL AWAY FROM FUTURE DRIVEWAY AREAS, CONCRETE STOOPS AND COURTESY WALKS.
13. ABANDONMENT OF SERVICE, SEE VILLAGE CODE SEC. 22.203.1
14. ALL STREET EXCAVATIONS MUST BE BACKFILLED IN ACCORDANCE WITH THE I.D.O.T. STANDARDS FOR TRENCH BACKFILL AND SURFACE REPAIR. ALL STREETS MUST BE TEMPORARILY PATCHED WITH COLD MIX PATCH UNTIL SUCH TIME AS THEY CAN BE PERMANENTLY REPAIRED. IT IS THE CONTRACTORS RESPONSIBILITY TO NOTIFY THE HILLSIDE POLICE, FIRE DEPARTMENT AND PUBLIC WORKS DEPARTMENT OF ANY COMPLETE OR PARTIAL STREET CLOSINGS.

- **INSPECTION REQUESTS AND QUESTIONS REGARDING THE ABOVE SPECIFICATIONS SHOULD BE REFERRED TO THE HILLSIDE PUBLIC WORKS DEPARTMENT AT 708-202-3434.**