



VILLAGE OF HILLSIDE

PUBLIC WORKS & BUILDING SERVICES

DIRECTOR
Joseph L. Pisano

ASSISTANT DIRECTOR/PUBLIC WORKS
Paul J. Smith

FOREMAN/PUBLIC WORKS
Andre Kwiatek

CODE ENFORCEMENT OFFICER
Leonard P. Belmonte

425 North Hillside Avenue
HILLSIDE, ILLINOIS 60162
708/202-3434
FAX: 708/202-3432
www.hillside-il.org

VILLAGE OF HILLSIDE
CONSTRUCTION CODE
SEWER TAP SPECIFICATIONS

BUILDING INSPECTOR
Arthur W. Rubel

PLUMBING INSPECTOR
Jack Caruso

ELECTRICAL INSPECTOR
Willie Carter

CODE ENFORCEMENT OFFICER
Jimmie Lane

2022

1. SEWER CONNECTIONS TO THE VILLAGE MAIN MUST BE MADE WITH A SADDLE TYPE SEWER SERVICE "T" OR FLOW DIRECTIONAL WYE. THE VILLAGE'S EXISTING SANITARY SEWER MAIN MUST NOT BE DISTURBED.
2. POINT OF CONNECTION BETWEEN NON-JOINTED MATERIALS REQUIRE NON-SHEAR MISSION COUPLINGS.
3. A CEMENT COLLAR IS REQUIRED IN ADDITION TO NON-SHEAR MISSION COUPLINGS AT POINT OF CONNECTION FOR DISSIMILAR MATERIALS.
4. THE SEWER SERVICE LINE MUST BE 6" IN DIAMETER FOR RESIDENTIAL AND 8" FOR COMMERCIAL PROPERTIES. THE SEWER MUST BE INSTALLED AT LEAST 18" BELOW OR 10' LATERALLY FROM THE WATER SERVICE LINE.
5. ACCEPTABLE MATERIALS INCLUDE: CAST IRON, DUCTILE IRON OR POLY VINYL CHLORIDE SDR26.
6. IF SDR26 PVC PUSH JOINT SEWER PIPE IS USED IT MAY START FROM A POINT 5' OUTSIDE THE FOUNDATION WALL. NO SCHEDULE PIPE BELOW THIS SPECIFICATION IS ALLOWED.
7. A MINIMUM OF 6" OF SAND, FA6 OR APPROVED BACKFILL MUST BE USED AS BEDDING FOR THE SEWER SERVICE LINE.
8. A MINIMUM DRAIN SLOPE OF ¼" PER FOOT MUST BE MAINTAINED FOR SEWER PIPES.
9. FOR COMMERCIAL PROPERTIES AN INSPECTION MANHOLE MUST BE INSTALLED OUTSIDE THE PROPOSED FACILITY AS PER MWRD REQUIREMENTS. A STRAIGHT 6" "T" CLEAN-OUT MUST BE INSTALLED AT LEAST 5'-10' (FEET) AWAY FROM THE FOUNDATION WALL FOR RESIDENTIAL HOUSES.
10. THE TRENCH FOR THE SANITARY SEWER SERVICE LINE MUST BE KEPT AWAY FROM THE FUTURE DRIVEWAY AREA AND CONCRETE FRONT STOOP AREA.
11. ALL TAPS, CONNECTIONS AND LOCATIONS MUST BE INSPECTED BY THE HILLSIDE PUBLIC WORKS DEPARTMENT PRIOR TO BACKFILLING.
12. SUMP PUMP DISCHARGE PIPES MUST BE ROUTED TO THE OUTSIDE OF THE HOUSE AND DISCHARGE TO THE GROUND SURFACE OR DIRECTLY INTO THE VILLAGE STORM SEWER SYSTEM. THE DISCHARGE LOCATION MUST DRAIN TO THE OWNERS PROPERTY AND MUST NOT FLOOD A NEIGHBORING PROPERTY OR VILLAGE STREET AND/OR SIDEWALK. NO SUMP PUMP DISCHARGE CONNECTION WILL BE ALLOWED TO THE SANITARY SEWER.
13. IF AN EJECTOR PUMP IS INSTALLED, NO GROUND WATER CONNECTIONS ARE ALLOWED INTO THE EJECTOR PIT. EXAMPLES: FOUNDATION DRAINS, DOWNSPOUTS, WINDOW WELL DRAINS, AND DRIVEWAY DRAINS. ONLY WASTE WATER CONNECTIONS ARE ALLOWED INTO THE EJECTOR PUMP PIT.
14. ABANDONMENT OF SERVICE: SEE VILLAGE CODE SEC. 22.203.1
15. ALL STREET EXCAVATIONS MUST BE BACKFILLED IN ACCORDANCE WITH THE I.D.O.T. STANDARDS FOR TRENCH BACKFILL AND SURFACE REPAIR. ALL STREETS MUST BE TEMPORARILY PATCHED WITH COLD MIX ASPHALT PATCH UNTIL SUCH TIME AS THEY CAN BE PERMANENTLY REPAIRED. IT IS THE CONTRACTORS RESPONSIBILITY TO NOTIFY THE HILLSIDE POLICE, FIRE DEPARTMENT AND PUBLIC WORKS DEPARTMENT OF ANY COMPLETE OR PARTIAL STREET CLOSINGS.

- **INSPECTION REQUESTS AND QUESTIONS REGARDING THE ABOVE SPECIFICATIONS SHOULD BE REFERRED TO THE HILLSIDE PUBLIC WORKS DEPARTMENT AT 708-202-3434.**